

UNT AGL COPPER SPECIAL FLEX - B

BAKIR BANT EKLANLI ÖZEL ESNEK PRİMER PİST AYDINLATMA KABLOSU – TİP B
SPECIAL FLEXIBLE PRIMARY AIRPORT LIGHTING CABLE WITH COPPER TAPE SCREEN – TYPE B

ICEA S-93-639 / NEMA WC74

FAA – L 824 (AC - 150/5375-7E SPECIFICATION FOR L-824)

KABLO YAPISI

- * İLETKEN : Tavlı Bakır İletken (Tip TCC) veya Kalaylı (Tip BCC) Bakır İletken - IEC C 60228 CL 2' ye göre
- * İZOLE : EPR Kauçuk - ICEA S-93-639 / NEMA WC74' e göre
- * EKLAN : Minimum %20 bindirmeli ve %100 kapamalı olarak helisel uygulanmış Bakır Bant
- * DIŞ KILIF : PCP veya esdeğeri malzeme - ICEA S-93-639 / NEMA WC74' e göre

CABLE STRUCTURE

- * CONDUCTOR : Strand of annealed tinned copper wires (Type TBC) or plain copper wires (Type BBC) according to IEC C 60228 CL 2
- * INSULATION : EPR Rubber according to ICEA S-93-639 / NEMA WC74
- * SCREEN : Minimum 20% overleap and 100% coverage ratio helically applied Copper Tape
- * OUTER JACKET : PCP or equivalent material according to ICEA S-93-639 / NEMA WC74



ÇALIŞMA KARAKTERİSTİKLERİ / OPERATING CHARACTERISTICS

- ÇALIŞMA SICAKLIĞI / CONDUCTOR OPERATING TEMPERATURE : -25 / +90°C
- ÇALIŞMA GERİLİMİ / RATED VOLTAGE : 5 kV
- TEST GERİLİMİ / TEST VOLTAGE : 18 kV
- BÜKME YARI ÇAPI / BENDING RADIUS : 12 x Outer Diameter
- TEST STANDARDI / STANDARD OF TEST : ICEA S-93-659 / NEMA WC74

Tüm kesitler AWG ve Metrik olarak sağlanabilir.
All sizes are available in AWG and Metric